



James J. Hirsch & Associates

12185 Presilla Road
Camarillo, California 93012-9243
(805) 553-9000 fax: (805) 532-2401 email: James.J.Hirsch@gmail.com

6 October 2016

Commercial Software List
Department of Energy
Office of Building Technologies, EE-2J
1000 Independence Ave., SW
Washington, DC 20585-0121

Commercial Software List
Ron Judkoff
National Renewable Energy Laboratory
15013 Denver West Parkway
Golden, CO 80401

To Whom It May Concern:

Enclosed herewith is our DOE-2.2 submittal for Qualified Computer Software for calculating Energy Savings for Purposes of Energy-Efficient Commercial Building Tax Deduction under Internal Revenue Section §179D.

Software Developer: James J. Hirsch & Associates
12185 Presilla Road
Camarillo, California 93012-9243
www.doe2.com

Contact Person: James J. Hirsch
Jeff.Hirsch@DOE2.com
805-553-9000 (phone)
805-532-2401 (fax)

Software Version: DOE-2.2 48y

The software has been tested according to ANSI/ASHRAE Standard 140-2014: Standard Method of Test for the Evaluation of Building Energy Analysis Computer Programs (except for sections 5.2.4, 7, and 8). The enclosed DVD contains files that include all test results, input files, output files, weather data, modeler reports, post-processor programs, and a complete installation program from which DOE-2.2 48y can be installed.

Please contact me at the phone or email address provided if I can answer any question.

Cordially,

James J. Hirsch

Attachment 1

Tax Deduction Qualified Software for buildings placed in service on or after January 1, 2016.

DOE-2.2 version 48y

On this page you'll find information about the DOE-2.2 version 48y Qualified Software for Calculating Commercial Building Tax Deductions | Department of Energy <http://energy.gov/eere/buildings/qualified-software-calculating-commercial-building-tax-deductions>, which calculates energy and power cost savings that meet federal tax incentive requirements for commercial buildings.

Statements and information in the right hand column of this table are from the software developer.

Internal Revenue Code §179D (c)(1) and (d) Regulations Notice 2006-52, Section 6 requirements as amplified by Notice 2008-40, Section 4 requirements.	
(1) The name, address, and (if applicable) web site of the software developer;	James J. Hirsch & Associates 12185 Presilla Road Camarillo, California 93012-9243 www.doe2.com
(2) The name, email address, and telephone number of the person to contact for further information regarding the software;	Jeff Hirsch James J. Hirsch & Associates Jeff.Hirsch@DOE2.com 805-553-9000 (phone) 805-532-2401 (fax)
(3) The name, version, or other identifier of the software as it will appear on the list;	DOE-2.2 48y
(4) All test results, input files, output files, weather data, modeler reports, and the executable version of the software with which the tests were conducted; and	Provided to DOE
(5) A declaration by the developer of the software, made under penalties of perjury, that—	
(a) The software has been tested according to ANSI/ASHRAE Standard 140-2007 Standard Method of Test for the Evaluation of Building Energy Analysis Computer Programs;	"The software has been tested according to ANSI/ASHRAE Standard 140-2007 Standard Method of Test for the Evaluation of Building Energy Analysis Computer Programs."
(b) The software can model explicitly—	
(i) 8,760 hours per year;	"The DOE-2.2 48y software complies."
(ii) Calculation methodologies for the building components being modeled;	"The DOE-2.2 48y software complies."
(iii) Hourly variations in occupancy, lighting power, miscellaneous equipment power, thermostat setpoints, and HVAC system operation, defined separately for each day of the week and holidays;	"The DOE-2.2 48y software complies."
(iv) Thermal mass effects;	"The DOE-2.2 48y software complies."
(v) Ten or more thermal zones;	"The DOE-2.2 48y software complies."
(vi) Part-load performance curves for mechanical equipment;	"The DOE-2.2 48y software complies."
(vii) Capacity and efficiency correction curves for mechanical heating and cooling equipment; and	"The DOE-2.2 48y software complies."
(viii) Air-side and water-side economizers with integrated control.	"The DOE-2.2 48y software complies with the air-side economizer requirements and with two forms of water-side economizers (WSE): dedicated WSE

Attachment 1 (continued)

	coils in air handlers and 'parallel' (i.e., non-integrated) WSE such as a strainer cycle. The DOE-2.2 48y software cannot model 'parallel' WSE (i.e., with integrated control) and shall not be used for projects with that technology."
(c) The software can explicitly model each of the following HVAC systems listed in Appendix G of Standard 90.1-2004:	
(i) Packaged Terminal Air Conditioner (PTAC) (air source), single-zone package (through the wall), multi-zone hydronic loop, air-to-air DX coil cooling, central boiler, hot water coil.	"The DOE-2.2 48y software complies."
(ii) Packaged Terminal Heat Pump (PTHP) (air source), single-zone package (through the wall), air-to-air DX coil heat/cool.	"The DOE-2.2 48y software complies."
(iii) Packaged Single Zone Air Conditioner (PSZ-AC), single-zone air, air-to-air DX coil cool, gas coil, constant-speed fan.	"The DOE-2.2 48y software complies."
(iv) Packaged Single Zone Heat Pump (PSZ-HP), single-zone air, air-to-air DX coil cool/heat, constant-speed fan.	"The DOE-2.2 48y software complies."
(v) Packaged Variable-Air-Volume (PVAV) with reheat, multi-zone hydronic loop, air-to-air DX coil, VAV fan, boiler, hot water VAV terminal boxes.	"The DOE-2.2 48y software complies."
(vi) Packaged Variable-Air-Volume with parallel fan powered boxes (PVAV with PFP boxes), multi-zone air, DX coil, VAV fan, fan-powered induction boxes, electric reheat.	"The DOE-2.2 48y software complies."
(vii) Variable-Air-Volume (VAV) with reheat, multi-zone air; multi-zone hydronic loop, air-handling unit, chilled water coil, hot water coil, VAV fan, chiller, boiler, hot water VAV boxes.	"The DOE-2.2 48y software complies."
(viii) Variable-Air-Volume with parallel fan powered boxes (VAV with PFP boxes), multi-zone air, air-handling unit, chilled water coil, hot water coil, VAV fan, chiller, fan-powered induction boxes, electric reheat.	"The DOE-2.2 48y software complies."
(d) The software can—	
(i) Either directly determine energy and power costs or produce hourly reports of energy use by energy source suitable for determining energy and power costs separately; and	"The DOE-2.2 48y software complies."
(ii) Design load calculations to determine required HVAC equipment capacities and air and water flow rates.	"The DOE-2.2 48y software complies."
(e) The software can explicitly model:	
(i) Natural ventilation.	"The DOE-2.2 48y software can model simple single-zone natural ventilation using air changes per hour (user-defined) or Sherman-Grimsrud (calculated)."
(ii) Mixed mode (natural and mechanical) ventilation.	"The DOE-2.2 48y software does not explicitly model this feature and shall not be used for projects with that technology."
(iii) Earth tempering of outdoor air.	"The DOE-2.2 48y software does not explicitly model this feature and shall not be used for projects with that technology."
(iv) Displacement ventilation.	"The DOE-2.2 48y software does not explicitly model this feature and shall not be used for projects with that technology."
(v) Evaporative cooling.	"The DOE-2.2 48y software complies."
(vi) Water use by occupants for cooking, cleaning or other domestic uses.	"The DOE-2.2 48y software does not explicitly model this feature and

Attachment 1 (continued)

	shall not be used for projects with that technology."
(vii) Water use by heating, cooling, or other equipment, or for on-site landscaping.	"The DOE-2.2 48y software does not explicitly model this feature and shall not be used for projects with that technology."
(viii) Automatic interior or exterior lighting controls (such as occupancy, photocells, or time-clocks).	"The DOE-2.2 48y software can explicitly model automatic interior or exterior lighting controls such as occupancy sensors or time-clocks, but cannot model photocells."
(ix) Daylighting (sidelighting, skylights, or tubular daylight devices).	"The DOE-2.2 48y software complies."
(x) Improved fan system efficiency through static pressure reset.	"The DOE-2.2 48y software does not explicitly model this feature and shall not be used for projects with that technology."
(xi) Radiant heating or cooling (low or high temperature).	"The DOE-2.2 48y software complies with the radiant system requirements for low delta-t heating panel applications. The DOE-2.2 48y software does not explicitly model radiant cooling systems or high temperature radiant heating systems and shall not be used for projects with that technology."
(xii) Multiple or variable-speed control for fans, cooling equipment, or cooling towers.	"The DOE-2.2 48y software complies."
(xiii) On-site energy systems (such as combined heat and power systems, fuel cells, solar photovoltaic, solar thermal, or wind).	"The DOE-2.2 48y software can model on-site energy systems including engines, gas turbines, steam turbine generators and photovoltaic arrays. DOE-2.2 48y cannot model fuel cells, solar thermal, or wind systems and shall not be used for projects with these technologies."












- 1) 90.1-2007 is defined by the PATH Act of 2015 as "Standard 90.1-2007 of ASHRAE and IESNA (as in effect on the day before the date of the adoption of Standard 90.1-2010 of such Societies)." This definition includes 90.1-2007 and the addenda supplement package (Addenda a, b, c, g, h, i, j, k, l, m, n, p, q, s, t, u, w, y, ad, and aw) and addendum r, plus all published errata.
- 2) Software that cannot explicitly model one or more of the HVAC systems or features in sections 5.c and 5.e of the table can still be listed as qualified software. It cannot, however, be used for 179D analyses of projects that need to model such systems or features. When this is the case, the statement used for the particular requirements shall be as follows: The *AAA EnergySoftware* cannot model *system or feature X* and shall not be used for projects with this technology.

Tax Deduction Qualified Software — <http://energy.gov/eere/buildings/qualified-software-calculating-commercial-building-tax-deductions>

Attachment 2

Contents of the enclosed DVD

The following folders and files are provided on the enclosed DVD:












-  ExecutableSoftware
-  ModelerReports
-  ProjectFiles-Input+Output
 -  Batchprocessing Files
 -  Input+ Output Files
 -  Sec5-2
 -  Sec5-3
 -  Sec5-3B
 -  Sec5-4
-  Results
-  WeatherData

At the root of the CD file structure:

- Electronic (PDF) copy of this application letter

- Electronic copy (MS Word format) IRS-required software information

Folders and subfolders:

-  ExecutableSoftware
 - A complete DOE-2.2 v48y setup.exe installation file
-  ModelerReports
 - Modeler's notes (MS Word docs)
-  ProjectFiles-Input+ Output
 -  Batchprocessing Files
 - A postprocessor (D2ResToXLS.exe) used to automatically retrieve the run results and populate the results spreadsheets plus input file scripts for the batch run process
-  Input+ Output Files
 -  Sec5-2
 -  Sec5-3
 -  Sec5-3B
 -  Sec5-4
 - Input & output files for each of the four Std 140 sections
-  Results
 - Compiled results, one Excel spreadsheet file for each of the four Std 140 sections
-  WeatherData
 - ASCII and binary weather data files used in the simulation runs